

PYROGRILLE 100 FIRE TEST DATA AS AT JANUARY 2019

SUBSTRATE	MAX SIZE	FIRE RATING	TEST STANDARD	REPORT NO.
PLASTERBOARD WALL	Up to 600x600 /600 diameter	120 minutes	BS 476 PT.20 1987	WF REPORT 391348
BRICK / BLOCK WALL	Up to 600x600 /600 diameter	120 minutes	BS 476 PT.20 1987	WF REPORT 391348
Sizes larger than 600x600				
PLASTERBOARD WALL	Up to 600x750 or 750x600 Up to 850x200	60 minutes	BS 476 PT.20 1987	WFA 407822 ISSUE 2
BRICK / BLOCK WALL	Up to 600x750 or 750x600 Up to 850x200	60 minutes	BS 476 PT.20 1987	WFA 407822 ISSUE 2
DOORS				
FIRE DOOR (FD30)	Up to 600x600	30 minutes	BS EN 1634-1 2014	WF REPORT 391351
FIRE DOOR (FD60)	Up to 600x600	60 minutes	BS EN 1634-1 2014	WF REPORT 391351
Sizes larger than 600x600				
FIRE DOOR (FD30)	Up to 600x750 or 750x600	30 minutes	BS 476 PT.20 1987	WFA 407822 ISSUE 2
FIRE DOOR (FD60)	Up to 600x690 or 690x600	60 minutes	BS 476 PT.20 1987	WFA 407822 ISSUE 2