
CERTIFICATE OF APPROVAL

No CF 564

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

LORIENT POLYPRODUCTS LIMITED

Fairfax Road, Heathfield Industrial Estate, Newton Abbot,
Devon, TQ12 6UD

Tel: 01626 834252 Fax: 01626 833166

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

Lorient Non-vision Style LVN20,
LVN25, Vision Style LVV40,
LVC40 and High Performance
Vision Style LVH44, LVHC44 Air
Transfer Grilles

Lorient LVN20S, LVN25S and
LVV40S Air Transfer and Smoke
Control Grilles

TECHNICAL SCHEDULE

TS47 – Intumescent Air
Transfer Grilles

Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification



Sir Ken Knight
Chairman
Impartiality Committee



Paul Duggan
Certification Manager

Issued: 19th August 2008
Reissued: 9th May 2017
Next audit test due: 09/05/2020
Frequency: Every 3 years
Valid to: 8th May 2022

Page 1 of 8



CERTIFICATE No CF 564

LORIENT POLYPRODUCTS LIMITED

LORIENT AIR TRANSFER GRILLES – LVN20, LVN25, LVV40, LVC40, LVH44 & LVHC44 LORIENT AIR TRANSFER AND SMOKE CONTROL GRILLES – LVN20S, LVN25S & LVV40S

1. Lorient air transfer grilles comprise a range of vision style and non-vision intumescent based grilles of differing thicknesses, applications and intumescent types. They are available in rectangular and circular shapes over a range of sizes for up to 600 mm square, dependant on grille type and fire resistance period required. The use of ferrous or non-ferrous metal cover grilles is optional. Full details of the applications and their requirements are given in later parts of this certificate.
2. The air transfer grilles are approved on the basis of:
 - i) A design appraisal against TS47
 - ii) Initial type testing
 - iii) Manufacturing frequency checks
 - iv) Ageing and durability tests
 - v) Evidence of technical support
 - vi) Clear and unambiguous labelling of grilles
 - vii) Production surveillance under ISO 9001: 2008
 - viii) On-going audit tests in accordance with TS47
3. The air transfer grilles are suitable to be used as follows: -
 - LVN20**
 - Installed within CERTIFIRE approved FD30 timber based doorsets
 - LVN20S**
 - Installed within CERTIFIRE approved FD30S timber based doorsets
 - Installed within CERTIFIRE approved FD60S timber based doorsets
 - LVN25**
 - Installed within CERTIFIRE approved FD30 timber based doorsets (subject to leaf thickness)
 - Installed within CERTIFIRE approved FD60 timber based doorsets
 - LVN25S**
 - Installed within CERTIFIRE approved FD30S timber based doorsets (subject to leaf thickness)
 - Installed within CERTIFIRE approved FD60S timber based doorsets
 - LVV40/LVC40**
 - Installed within CERTIFIRE approved FD30 timber based doorsets
 - Installed within CERTIFIRE approved FD60 timber based doorsets
 - Installed within CERTIFIRE approved FD60 steel based doorsets
 - Installed within CERTIFIRE approved FD60 mineral composite cored doorsets
 - Installation within masonry walls for 60 minutes fire resistance periods.

CERTIFICATE No CF 564

LORIENT POLYPRODUCTS LIMITED

LORIENT AIR TRANSFER GRILLES – LVN20, LVN25, LVV40, LVC40, LVH44 & LVHC44
LORIENT AIR TRANSFER AND SMOKE CONTROL GRILLES – LVN20S, LVN25S & LVV40S

LVV40S

- Installation within masonry walls for up to 90 minutes fire resistance periods.

LVH44/LVHC44

- Installed within CERTIFIRE approved steel based doorsets for up to FD120
- Installed within CERTIFIRE approved mineral composite cored doorsets for up to FD120
- Installation within masonry walls and concrete floors for up to 120 minutes fire resistance periods.

4. Doorset assemblies and wall/floor assemblies into which the Lorient air transfer grilles are to be fitted shall be previously successfully tested to BS 476: Part 22: 1987 and must have incorporated an aperture (typically a glazed aperture in doors) of a size at least equal to that of the Lorient air transfer grille intended for installation. Failure to satisfy these criteria will invalidate the certification.
5. The suitability of the air transfer grilles in door assemblies not certificated by CERTIFIRE should be established by reference to the certification, test reports or assessments relating to the particular door assembly.
6. The Lorient air transfer grilles are approved for use in the following maximum sizes or areas:
 - LVN20 any rectangular shape up to a maximum area of 0.2025 m²
 - LVN20S any rectangular shape up to a maximum area of 0.16 m²
 - LVN25 any rectangular shape up to a maximum area of 0.2025 m²
 - LVN25S any rectangular shape up to a maximum area of 0.16 m²
 - LVV40 up to 600 mm by 600 mm
 - LVV40S any rectangular shape up to a maximum area of 0.2025 m²
 - LVC40 up to 600 mm diameter
 - LVH44 any rectangular shape up to a maximum area of 0.2025 m²
 - LVHC44 up to 465 mm diameter

CERTIFICATE No CF 564

LORIENT POLYPRODUCTS LIMITED

LORIENT AIR TRANSFER GRILLES – LVN20, LVN25, LVV40, LVC40, LVH44 & LVHC44
LORIENT AIR TRANSFER AND SMOKE CONTROL GRILLES – LVN20S, LVN25S & LVV40S

Timber doorsets - LVN20, LVN20S, LVN25, LVN25S, LVV40 and LVC40

7. The LVN20, LVN20S, LVN25, LVN25S, LVV40 and LVC40 air transfer grilles are approved for installation within timber based doorsets for 30 minutes integrity performances, subject to the following requirements:

If the door leaf core does not comprise a solid timber lamel core (i.e. a core of chipboard, flaxboard etc.), the aperture provided in the leaf should be lined to full width using hardwood, with a minimum density of 650 kg/m^3 and a thickness of at least 6 mm. This hardwood liner may be omitted should the leaf have been tested.

- Approval of the LVN25 and LVN25S grilles in FD30 doorsets is limited to doorsets having door leaves with a minimum leaf thickness of 50 mm.
- The air transfer grille will be bedded onto a layer of LORIENT acrylic intumescent mastic.
- All grilles shall be installed subject to the positional limitations given later in this approval.

The LVN20S, LVN25, LVN25S, LVV40 and LVC40 air transfer grilles are approved for installation within timber based doorsets for 60 minutes integrity performances, subject to the following requirements:

- If the door leaf core does not comprise a solid timber lamel core (i.e. a core of chipboard, flaxboard etc.), the aperture provided in the leaf should be lined to full width using hardwood, with a minimum density of 650 kg/m^3 and a thickness of at least 6 mm. This hardwood liner may be omitted should the leaf have been tested with the aperture unlined.
- The air transfer grille will be bedded onto a layer of LORIENT acrylic intumescent mastic.
- All grilles shall be installed subject to the positional limitations given later in this approval.

In all applications where cold smoke leakage compliance is required, the LVN20S and LVN25S shall only be fitted to proven FD30/60S compliant doorsets.

CERTIFICATE No CF 564

LORIENT POLYPRODUCTS LIMITED

LORIENT AIR TRANSFER GRILLES – LVN20, LVN25, LVV40, LVC40, LVH44 & LVHC44
LORIENT AIR TRANSFER AND SMOKE CONTROL GRILLES – LVN20S, LVN25S & LVV40S

Steel based or mineral composite cored doorsets - LVV40 and LVC40

8. The LVV40 and LVC40 air transfer grilles are approved for installation within steel based or rigid mineral cored doorsets for up to 60 minutes integrity performances, subject to the following requirements:
- The air transfer grille will be bedded onto a layer of LORIENT acrylic intumescent mastic.
 - The grilles shall not be fitted into steel based doorsets with core materials of Polyurethane foam, Polyisocyanurate foam or Polystyrene unless there is test evidence from a UKAS laboratory validating the doorsets use for the required period when incorporating apertures of similar dimensions.

Steel based or mineral composite cored doorsets - LVH44 and LVHC44

9. The LVH44 and LVHC44 air transfer grilles are approved for installation within steel based or rigid mineral cored doorsets for up to 120 minutes integrity performances, subject to the following requirements:
- The aperture within the door leaf shall be lined with a LORIENT “LX4404” intumescent seal prior to installation of the air transfer grille.
 - The grilles shall be limited to use with doorsets having a minimum leaf thickness of 44 mm.
 - The grilles shall not be fitted into steel based doorsets with core materials of Polyurethane foam, Polyisocyanurate foam or Polystyrene unless there is test evidence from a UKAS laboratory validating the doorsets use for the required period when incorporating apertures of similar dimensions.

CERTIFICATE No CF 564

LORIENT POLYPRODUCTS LIMITED

LORIENT AIR TRANSFER GRILLES – LVN20, LVN25, LVV40, LVC40, LVH44 & LVHC44
LORIENT AIR TRANSFER AND SMOKE CONTROL GRILLES – LVN20S, LVN25S & LVV40S

Installation within masonry walls - LVV40, LVV40S and LVC40

10. The LVV40, LVV40S and LVC40 air transfer grilles are approved for installation directly into masonry walls, or when mounted within non-combustible framing for up to 60 minutes and 90 minutes (LVV40S) integrity performances, subject to the following requirements:
- When fitted directly within an aperture within a masonry wall the air transfer grille will be bedded onto a layer of LORIENT acrylic based intumescent mastic.
 - Where the option for non-combustible framing is chosen the framing shall have a minimum thickness 25 mm and width equal to that of the supporting construction. The framing shall be formed from materials of a rigid non-combustible nature only, i.e. 'Thermax' or 'Supalux' boards are acceptable.
 - The framing and/or grille shall be fixed using steel mechanical fixings.

Installation within masonry walls or concrete floors – LVH44 and LVHC44

11. The LVH44 and LVHC44 air transfer grilles are approved for installation directly into masonry walls and concrete floor, or when mounted within non-combustible framing for up to 120 minutes integrity performances, subject to the following requirements:
- When fitted directly within an aperture within a masonry wall the air transfer grille will be bedded onto a layer of LORIENT acrylic based intumescent mastic.
 - Where the option for non-combustible framing is chosen the framing shall have a minimum thickness 25 mm and width equal to that of the supporting construction. The framing shall be formed from materials of a rigid non-combustible nature only, i.e. 'Thermax' or 'Supalux' boards are acceptable.
 - Grilles mounted within concrete floors shall be supported by steel angles around the full perimeter of the aperture fixed back to the concrete with steel mechanical fixings.

Optional features

12. Additional ferrous or non-ferrous metal cover grilles may be added to the LVN20, LVN25, LVV40, LVC40, LVH44 and LVHC44 air transfer grilles. Only cover grilles supplied by the manufacturer and fitted in accordance with the manufacturer's instructions shall be acceptable.

CERTIFICATE No CF 564

LORIENT POLYPRODUCTS LIMITED

LORIENT AIR TRANSFER GRILLES – LVN20, LVN25, LVV40, LVC40, LVH44 & LVHC44
LORIENT AIR TRANSFER AND SMOKE CONTROL GRILLES – LVN20S, LVN25S & LVV40S

13. In all instances the air transfer grilles shall be installed and fixed in accordance with the manufacturer's instructions.

Positional requirements

14. The following positional limitations shall be applied to all vertical applications regardless of the type of construction the grille is installed within.

LVN20, LVN20S, LVN25 and LVN25S	The upper edge of the grill shall be no higher than 800 mm from floor level.
LVV40, LVV40S and LVC40	The upper edge of the grill shall be no higher than 3000 mm from floor level. The lower edge of the grille shall be no closer than 400 mm to floor level.
LVH44 and LVHC44	The upper edge of the grill shall be no higher than 3000 mm from floor level. The lower edge of the grille shall be no closer than 200 mm to floor level.

15. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number (i.e. CF 564) and application where appropriate.

16. The following table shows the acceptable applications and fire resistance periods for the different grilles:

Door Type	Approved applications - door assemblies							
	LVN20	LVN20S	LVN25	LVN25S	LVV40	LVC40	LVH44	LVHC44
FD30 Timber door	✓	✓	✓*	✓*	✓	✓	✗	✗
FD30S Timber door	✗	✓	✗	✓*	✗	✗	✗	✗
FD60 Timber door	✗	✓	✓	✓	✓	✓	✗	✗
FD60S Timber door	✗	✓	✗	✓	✗	✗	✗	✗
FD60 Steel door	✗	✗	✗	✗	✓	✓	✓	✓
FD60 Mineral composite door	✗	✗	✗	✗	✓	✓	✓	✓
FD120 Mineral composite door	✗	✗	✗	✗	✗	✗	✓	✓
FD120 Steel door	✗	✗	✗	✗	✗	✗	✓	✓

* Subject to a minimum leaf thickness of 50 mm.

Page 7 of 8 Signed
E/108



Issued: 19th August 2008
 Reissued: 9th May 2017
 Valid to: 8th May 2022

CERTIFICATE No CF 564

LORIENT POLYPRODUCTS LIMITED

LORIENT AIR TRANSFER GRILLES – LVN20, LVN25, LVV40, LVC40, LVH44 & LVHC44
LORIENT AIR TRANSFER AND SMOKE CONTROL GRILLES – LVN20S, LVN25S & LVV40S

Approved applications – wall & floor assemblies				
Type	LVV40S	LVC40	LVH44	LVHC44
Masonry walls 60 minutes	✓	✓	✓	✓
Masonry walls 90 minutes	✓	✗	✓	✓
Masonry walls 120 minutes	✗	✗	✓	✓
Concrete floor 120 minutes	✗	✗	✓	✓

Further Information

Further information regarding the details contained in this certificate may be obtained from Lorient Polyproducts Limited (Tel: 01626 834252).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).